

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203821
Address: 1541 SW MANOR LAKE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Patrick Schonfeldt	Failed	Wednesday, January 20, 2021

Corrective Action Required:

1	Misc	-DO NOT COVER UNTIL FIRE RATING IS VERIFIED BY OFFICE-
		CURRENTLY HAVE (1) LAYER 5/8" SCREW PATTERN LESS THAN 6" EDGE 12" FIELD

Comments: