

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20200522  
Address: 3229 SW MARY ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	John Morris	Temporary C of O	Thursday, January 21, 2021

Corrective Action Required:

1	Misc	-Final grade and sod per approved plot -Remove excavation spoils from site -remove debris from street & sidewalk -Seal top and sides of exterior lighting exposed to the elements
---	------	--

TCO VALID THROUGH 02/21/2021

**Comments:**