

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201526
Address: 1528 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Temporary C of O	Thursday, January 21, 2021

Corrective Action Required:

1	Misc	*TCO UNTIL 3-15-21
		-Final grade and sod per approved plot -Maintain minimum 6" of fall 10' from foundation -Maintain erosion control until sod is in place

Comments: