

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201084
Address: 1524 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, January 21, 2021

Corrective Action Required:

1	Misc	-sod -As graded plot plan failed due to stock piles from trenching on adjacent lot-recall when corrected -Address NM against b vent at furnace, minimum 1" clearance required-Use permanent fastening method
---	------	--

Comments: