

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203429
Address: 2926 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Thursday, January 21, 2021

Corrective Action Required:

1	Misc	-Seal all top plate penetrations-garage-west wall -LIB bracing all locations per plans -(2) 2x4 per plans at mud entry and owner entry, per plans -properly support 2nd floor stair landing -3" SCH 40 steel column at pier location "A" stair wall per plans -Nail exterior sheathing per plans 6" edge, 12" field -Install basement egress window per plans
---	------	---

Comments: