

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20201012  
Address: 1866 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Temporary C of O	Thursday, January 21, 2021

Corrective Action Required:

1	Misc	-Obtain lawn irrigation permit and submit the backflow test report to city -Final grade, sod, downspout and sump pump extensions -Seal exterior wall penetrations, seal above AC disconnect, meter, etc -Support loose receptacle yoke at front entry -Sewer cleanout must be accessible
---	------	--

Comments: