

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20204589

Address: 196 NW OLDHAM PKWY, Unit:B, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Plumbing Inspection - Commercial</b>	Michael Harkins	Pending	

Corrective Action Required:

1	Misc	- PROVIDE SUPPORT PEX WATER LINES - - PROVIDE PLUMBING PROTECTION PLATES PEX & DWV - - NO FURTHER INSPECTIONS UNTIL PLUMBER IS LISTED ON THE PERMIT -
---	------	---

**Comments:**