CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204231

Address: 102 NW GRADY CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Underslab Plumbing Inspection Michael Harkins Pending

- Residential

Corrective Action Required:

1 Misc - PROVIDE PERIMETER INTERIOR UNDERSLAB DRAIN TILE -

- R506.2.5 / SEC 7-919

Comments: