

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203429
Address: 2926 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Friday, January 22, 2021

Corrective Action Required:

1 Misc

***OK to insulate

-3" SCH 40 steel column at pier location "A" stair wall per plans-Provide clarification as plans show (3) 2x4 and schedule calls for SCH 40 column— Address also that current 2x4 post is only supporting 1 member of double joist carrying point load from above
-Nail exterior sheathing per plans 6" edge, 12" field-check SW corner seam and edges by egress window and seams on west side
-Install basement egress window per plans

Comments: