

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20193544  
Address: 2001 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Michael Harkins	Failed	Friday, January 22, 2021

Corrective Action Required:

1	Miscellaneous Correction	Provide covers open j boxes throughout Room / Door # 107,108, 109,116, 125,127, 135, 143, RO room, IT room, treatment areas, Ok to install borders must provide access to above rooms with open j boxes
---	-----------------------------	--

**Comments:**