


Jan 22, 2021

Summit Homes 120 SE 30<sup>th</sup> St. Lee's Summit, MO 64082

RE: Clarification of support at footing for Lot # 60 Hawthorne Ridge – 2926 SW Arbor Tree Dr. Lee's Summit, MO 64082 – Permit # PRRES20203429

This letter clarifies the support at footing for Lot # 60 Hawthorne Ridge.

• It is structurally acceptable to support the main floor point load of 2.9 kips from (2) 1-3/4" x 9-1/4" LVL flush with (3) #2 2x4 Douglas fir larch at the stairs on the basement level with an "A" size footing within the grade beam as shown below.



Sincerely,

Bradley Huxol, PE