

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202818
Address: 1704 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Monday, January 25, 2021

Corrective Action Required:

1	Misc	-Lag bolts at deck ledger per code, attach ledger to cantilever per detail 10 S2.0 in plans
---	------	---

****OK TO INSULATE AND ROCK****

Comments: