

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200102
Address: 2308 SW CHASE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Monday, January 25, 2021

Corrective Action Required:

1	Misc	-E3902.16 AFCI protection - branch circuits that supply 120 volt, single phase, 15 and 20 volt amp outlets installed in kitchens, family rooms, dining rooms, living rooms, parlors, libraries, dens, bedrooms, sunrooms, recreation rooms, closets, hallways, laundry areas and any similar areas. -AC COMPRESSOR CIRCUIT PROTECTION MIN 31.9 AMP, MAX OVERCURRENT 50 AMP -SECURE AC ELECTRICAL WHIP WITHIN 12" OF DISCONNECT -SEAL ALL PENETRATIONS IN SIDING, SEAL ALONG TOP OF METER CAN AND AC DISCONNECT
---	------	---

Comments: