

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201862
Address: 1812 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Patrick Schonfeldt	Failed	Monday, January 25, 2021

Corrective Action Required:

1	DCM6 ESC INSP DENIED STREET CLEAN UP	REQUESTED INSPECTION(S) DENIED. STREET CLEAN UP REQUIRED IMMEDIATELY, AND SHALL BE COMPLETED PRIOR TO REQUESTED INSPECTION(S) BEING PERFORMED. -SILT FENCE REQUIRED AT FRONT OF LOT -STREET CLEANUP REQUIRED IMMEDIATELY AT MUD AND SILT IN STREET -INSTALL BARRIER FENCE AT TRENCH
---	--	--

ADDRESS ISSUES WITHIN 24 HOURS

Comments: