

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201863
Address: 3012 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Temporary C of O	Tuesday, January 26, 2021

Corrective Action Required:

1	Misc	-WATER METER LID TO BE EVEN WITH GRADE, MAINTAIN 14"-18" DISTANCE BETWEEN TOP OF METER AND LID -SOD LESS THAN 6" FROM SIDING ON WEST SIDE OF HOUSE -SEE PLOT PLAN INSPECTION REPORT CONCERNING NEGATIVE SLOPE ON WEST SIDE OF HOUSE, GRADE PER PLOT PLAN
---	------	--

OK FOR TCO - TCO EXPIRES 2/9/21

Comments: