

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204198
Address: 125 NW MACKENZIE DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	John Morris	Failed	Tuesday, January 26, 2021

Corrective Action Required:

2	Misc	-Erosion control requires continuous maintenance. Repair damaged sections within two business days, re-establish at front curb line -provide and maintain gravel filter -no further inspections until issues are resolved
---	------	---

Comments: