

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20201848  
Address: 1513 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                     | Inspector:         | Outcome: | Date:                     |
|-------------------------------------------------|--------------------|----------|---------------------------|
| <b>Occupancy Inspection - Codes Residential</b> | Patrick Schonfeldt | Failed   | Tuesday, January 26, 2021 |

Corrective Action Required:

|   |      |                                                                                                                                                                                                                |
|---|------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Misc | -See plot plan inspection report<br>-Complete stone/siding at front porch and garage<br>-complete drywall under garage door ceiling track attachment brackets<br>-Secure fallen HVAC duct brackets in basement |
|---|------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**Comments:**