

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE  
PROSECUTED**

---

**Permit #:** PRRES20201862  
**Address:** 1812 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

---

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Patrick Schonfeldt	Failed - Stop Work	Tuesday, January 26, 2021

**Corrective Action Required**

1	DCM6 ESC INSP DENIED STREET CLEAN UP	1/8/21 - REQUESTED INSPECTION(S) DENIED. STREET CLEAN UP REQUIRED IMMEDIATELY, AND SHALL BE COMPLETED PRIOR TO REQUESTED INSPECTION(S) BEING PERFORMED. -SILT FENCE REQUIRED AT FRONT OF LOT -STREET CLEANUP REQUIRED IMMEDIATELY AT MUD AND SILT IN STREET -INSTALL BARRIER FENCE AT TRENCH  1/25/21 - DISCUSSED ISSUES WITH CONTRACTOR AND ALLOWED 24 HOURS FOR CORRECTION  1/26/21 - STOP WORK ISSUED, ISSUES REMAIN, EROSION CONTROL SILT FENCE REQUIRED, STORM INLET PROTECTION REQUIRED, CLEAN MUD AND GRAVEL FROM STREET, SAFETY BARRIER AT OPEN TRENCH. NO ADDITIONAL WORK HAS TAKEN PLACE ON SEWER TRENCH SINCE 1/8/21 INSPECTION
---	---	---

**Comments:**

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201