

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRPWFC20173801
Address: 3500 SW HOLLYWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Grading/Excavation/Fill Inspection	John DiMauro	Passed	Monday, January 11, 2021

Informational:

1	PW-Misc	Matt Munger 01/31/2018 10:24 AM I spoke with KC Test Lab while they were on site, he stated they were getting 97% compaction on the north side of the property. On 1/30/18 KC Test was taking compaction tests approximately every 50-60ft on the north side.
---	---------	---

Comments: