

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRPWFC20173801  
Address: 3500 SW HOLLYWOOD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Invert</b>	John DiMauro	Passed	Monday, January 11, 2021

Informational:

1	PW-Misc	I came by this morning and talked with Daniel. They finished pouring the inverts for sanitary MH a-3 and a-4. I was not able to get back out in the afternoon, but jeremy and John went out for me in the afternoon. Steve Robbins 02/09/2018 3:44 PM
---	---------	---

Informational:

2	PW-Misc	Matt Munger 02/14/2018 9:57 AM I opened up MH A-3 and A-4 and observed the inverts that had been poured. The inverts were smooth and flowed in the proper direction.
---	---------	--

Informational:

3	PW-Misc	Matt Munger 02/15/2018 3:06 PM Opened up manholes B-1, B-2, B-3 and C-1. All inverts were smooth and formed correctly.
---	---------	---

I did see something in B-2 that I will have another inspector look at, at a later time. The invert at the upstream pipe looks as if there is a little bit of water sitting. Will return to do a follow up inspection to see if there is an issue.

Corrective Action Required:

4	PW-Misc	Matt Munger 02/16/2018 9:50 AM Tom C. and I looked at MH B-2 to double check the area that I was concerned about. Tom thought maybe the invert could be ground down a bit to avoid holding water.
---	---------	--

**Comments:**