

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRPWFC20173801
Address: 3500 SW HOLLYWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Storm - Outlet Structure	John DiMauro	Passed	Monday, January 11, 2021

Informational:

1 PW-Misc

Matt Munger 03/15/2018 11:30 AM

KAT had installed the flared end section and the toe wall. The length of the toe wall was approximately 24" and where the flared end section was set into the toe wall there was approximately 14" of toe wall exposed. Each side of the flared end section there was at least 15" of concrete on either side of the flared end section. The workers had not installed the rip rap just yet.

Comments: