

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRPWFC20173801
Address: 3500 SW HOLLYWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Curb - Compression Strength	John DiMauro	Partial	Monday, January 11, 2021

Informational:
1 PW-Misc John DiMauro 07/02/2018 8:44 AM

KC Testing Lab is on site taking samples of the curb concrete for compression testing.

Comments: