

Inspection Summary

Permit #: PRPWFC20173801, Public Works Infrastructure Permit - Commercial
Residences at Echelon
Address: 3500 SW HOLLYWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Coliform Test 2	John DiMauro	Partial	Thursday, May 09, 2019

Informational

1 We collected the day two samples for the 4" private domestic water line and delivered them to Keystone Labs.

We will know the results in 24 hours.

Informational

2 John DiMauro 05/09/2019 3:52 PM

We collected the day two samples for the 4" private domestic water line. I relinquished them to inspector Ron Paynter and he delivered them to Keystone Labs.

We will know the results in 24 hours.

The day 1 samples collected on 5/8/2019 passed.

Comments: