

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRPWFC20173801  
Address: 3500 SW HOLLYWOOD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Coliform Test 2</b>		Passed	Monday, January 11, 2021

Informational:  
1            Misc            We collected the day two samples for the 4" private domestic water line and delivered them to Keystone Labs.

We will know the results in 24 hours.

Informational:  
2            Misc            John DiMauro 05/09/2019 3:52 PM

We collected the day two samples for the 4" private domestic water line. I relinquished them to inspector Ron Paynter and he delivered them to Keystone Labs.

We will know the results in 24 hours.

The day 1 samples collected on 5/8/2019 passed.

Informational:  
3            Misc            We collected the day two samples for the 4" private domestic water line and delivered them to Keystone Labs.

We will know the results in 24 hours.

**Comments:**