

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRPWFC20173801
Address: 3500 SW HOLLYWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Coliform Test 2	John DiMauro	Partial	Thursday, May 09, 2019

Informational:
1 Misc We collected the day two samples for the 4" private domestic water line and delivered them to Keystone Labs.

We will know the results in 24 hours.

Informational:
2 Misc John DiMauro 05/09/2019 3:52 PM

We collected the day two samples for the 4" private domestic water line. I relinquished them to inspector Ron Paynter and he delivered them to Keystone Labs.

We will know the results in 24 hours.

The day 1 samples collected on 5/8/2019 passed.

Comments: