

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20201700

Address: 3521 SW MARKET ST, LEES SUMMIT, MO 640823500 SW MARKET ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Proof Roll</b>	Tom Taylor	Passed	Friday, December 04, 2020

Informational:

1 Misc

On Thursday, 12-03-2020. Barclays Asphalt installed geo-grid and rock sub-grade base on parking lot. There were areas that were soft and needed to be worked more. Most of the base passed the proof roll, however the contractor will repair any areas identified that failed before asphalt is placed.

**Comments:**