

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20201700

Address: 3521 SW MARKET ST, LEES SUMMIT, MO 640823500 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 2	Tom Taylor	Partial	Friday, December 11, 2020

Informational:

1	Misc	On Thursday, 12-03-2020. I took another water sample for bacteria test. Lab in Kansas.
---	------	--

Informational:

2	Misc	On Monday, 12-17-2020. The bacteria test taken on Thursday, failed and will be taken again.
---	------	---

Comments: