

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20201700

Address: 3521 SW MARKET ST, LEES SUMMIT, MO 640823500 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--------------------------------------|------------|----------|---------------------------|
| Water Line - Hydrostatic Test | Tom Taylor | Passed | Tuesday, October 20, 2020 |

Informational:

1 Misc

On Friday, 10-16-2020. John Jackson performed a hydrostatic pressure test on the fire line for this project. 200 lbs of pressure was introduced into line for (2) hours and held pressure passing the test. I was off and he filled in for me.

Comments: