

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20201700

Address: 3521 SW MARKET ST, LEES SUMMIT, MO 640823500 SW MARKET ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Coliform Test 1</b>	Tom Taylor	Partial	Friday, December 11, 2020

Informational:

1	Misc	On Wednesday, 12-02-2020. I took a water sample to the lab for bacteria testing.
---	------	--

Informational:

2	Misc	On Thursday, 12-03-2020. The bacteria test taken day prior, failed testing and will need to be re-taken.
---	------	--

**Comments:**