## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRSUBD20201700

Address: 3521 SW MARKET ST, LEES SUMMIT, MO 640823500 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:	
Water Line - Construction Inspection	<b>n</b> Tom Taylor	Passed	Tuesday, October 20, 2020	
Informational:				
1 Misc	_	Reinkie Excavating layer approx. 150 LF of 8" waterline with all necessary fittings and backfilled all applicable areas.		
Informational:				
2 Misc	water lines for wate	On Tuesday, 9-01-2020. The contractor pot holed areas to locate existing water lines for water line taps for Wednesday night main shut. All properties have been notified water shut.		
Informational:				
3 Misc		On Wednesday, 9-02-2020. Reike installed the water main "T" and placed approx 50 LF of 6" Waterline.		
Informational:				
4 Misc		-2020. Contractor comple aced across street. And ba	ted main connection at 12:00 am arricades were set.	
Informational:				
5 Misc	• •	18' of CG-I curbing. Contra	gh early concrete over street actor also installed 2" of asphalt	
Informational:	·			
6 Misc	• •	2020. The contractor laid a at was installed as well.	pprox. 30 LF of 6" waterline just	
Informational:				
7 Misc	On Monday, 10-19-2	020. I performed a water	line inspection on the 2"	

domestic and 4" cooper water line coming from the main. All inspections passed city standards.

Informational:

3 Misc

On 10-13-2020 Reike Construction installed Vault for back flow valve and installed (1) fire line valve . Also installed 30LF of  $6^{\prime\prime}$  pvc pipe w/ fittings.

## **Comments:**