

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200262
Address: 149 NW CARSON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Morris	Temporary C of O	Wednesday, January 27, 2021

Corrective Action Required:

1	Misc	-Lawn irrigation permit required -Provide sod -Seal top and sides of exterior lighting exposed to the elements, Electric meter enclosure, AC disconnect -Seal all exterior penetrations -Downspouts to discharge minimum 36 inches from foundation -Secure receptacle device to outlet box above exterior fireplace -Identify white insulated Conductors used as current carrying Conductors at both points of termination, Condensing unit circuit
---	------	---

TCO valid through 02/27/2021

Comments: