

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202544
Address: 1509 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, January 27, 2021

Corrective Action Required:

1	Misc	-Address field cut engineered truss in garage -submit engineer report on fix -Properly fasten double joist hanger(s), second floor framing above living room -Anchor bolt required within 12 inches a bottom plate splice, basement right of egress window **OK TO INSULATE**
---	------	--

Comments: