

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201668

Address: 159 SW M 150 HWY, LEES SUMMIT, MO 64082 155 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Patrick Schonfeldt	Failed	Wednesday, January 27, 2021

Corrective Action Required:

1	Misc	- SOD, FINAL GRADE - REMOVE ELECTRIC GFCI RECEPTACLE AND WIRING THAT HAS BEEN INSTALLED IN WATER METER WELL -
---	------	--

Corrective Action Required:

2	Miscellaneous Correction	-- AS PER A101 UL DESIGN U419 2 LAYERS IS REQUIRED ON BOTH SIDES OF WALL TO CLOSE THIS PERMIT. INCLUDING THE LABELING OF THE WALL.
---	--------------------------	--

Mike Weisenborn 01/13/2021 2:28 PM --- the architect of record provided a letter indicating the west side of the wall will be completed on the future tenant infill.

Comments: