

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201611
Address: 1713 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, January 28, 2021

Corrective Action Required:

1	Misc	****ALL DOORS TO HOUSE LOCKED AND NO LOCK BOX CODE PROVIDED**** -Seal top and bottom plate penetrations - front entry hall bath -Holes bored in floor joists for NM less than 2" from end of member, several locations throughout basement -NE Basement bath floor joist bored for pex and DWV less than 2" from end of joist and less than 2" apart
---	------	---

OK TO INSULATE - REMOVE INSULATION FROM ANY INSPECTION ITEMS

Comments: