

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20202025  
Address: 1421 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed	Thursday, January 28, 2021

Corrective Action Required:

1	Miscellaneous Correction	<b>**OK TO INSULATE**</b> -Protect vertical gas flex line at 1st floor closet per manufacturer installation instructions
---	--------------------------	---

**Comments:**