

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202579
Address: 4700 NE SARATOGA CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Residential	Khanh Nguyen	Failed	Thursday, January 28, 2021

Corrective Action Required:

1	Misc	-Nail sheathing to sill plates w/8d@3" oc; nail sheathing to lvl w/8"@3" grid pattern
---	------	---

Comments: