

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204535  
Address: 2029 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Residential</b>	Michael Harkins	Failed	Thursday, January 28, 2021

Corrective Action Required:

1	Misc	- PROVIDE DECK PIERS PER PLAN - - H 2X 16 X 36 W/ (4) #4 VERT BARS - - K 1X 24 X 36 W/ (4) #4 VERT BARS -  - FORM 18' ABOVE GRADE IS NOT 36" DEPTH -
---	------	--

**Comments:**