

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201707

Address: 2050 NW LOWENSTEIN DR, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Friday, January 29, 2021

Corrective Action Required:

1	Misc	- LICENSE TAX FEE NOT PAID - - REAR GRAB BARS 6" MAX FROM CORNER - - TEMP SINKS IN RESTROOMS NO SOAP, HAND DRYERS - - PROVIDE HEALTH DEPT INSPECTION REPORT - - PENDING INSPECTIONS : PLANNING, WATER UTILITIES, ENGINEERING, WATER SERVICE, -
---	------	--

Comments: