

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203429
Address: 2926 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection	Patrick Schonfeldt	Partial	Friday, January 29, 2021

Informational:
1 Misc -PARTIAL INSPECTION ON PEX FROM HOUSE ENTRANCE TO MID POINT FRONT YARD WHERE CONNECTION TO COPPER WILL TAKE PLACE

Comments: