

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20203599
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Hydrostatic Test	John DiMauro	Passed	Friday, January 29, 2021

Informational:

1 Misc

John DiMauro 1/29/21

I observed the Hydrostatic pressure test for water lines C & E. The gauge held at 150 psi for 2 hours with no drop.
Test Passed.

Comments: