

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20203599  
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Construction Inspection</b>	John DiMauro	Partial	Friday, January 29, 2021

Informational:  
3 Misc

John DiMauro 1/29/21

Following the hydrostatic pressure test, I observed the Redford crew chlorinate the water lines C & E. I verified the correct chlorine residual at the end of line test locations.

We will flush the line tomorrow morning.

**Comments:**