

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202666
Address: 4708 NE SARATOGA CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Khanh Nguyen	Failed	Friday, January 29, 2021

Corrective Action Required:

1	DCM2 ESC DEFICIENT INSTALLATION	DEFICIENT EROSION CONTROL INSTALLATION. INSPECTION DENIED -SILT FENCE NOT INSTALLED CORRECTLY. STAKES MUST BE ON STREET SIDE AND BOTTOM OF SILT FENCE MUST BE BURIED MIN 6" -STREET CLEAN UP OF GRAVEL AND MUD REQUIRED
---	---------------------------------------	--

Comments: