

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20201567  
Address: 4030 SW BENZIGER DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	John DiMauro	Passed	Friday, January 29, 2021

Corrective Action Required:  
1 Misc PRE POUR INSPECTION

The forms are set and there appears to be sufficient compacted aggregate.

**Comments:**