

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201498
Address: 140 NW MACKENZIE DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Ronald Paynter	Passed	Friday, January 29, 2021

Informational:
1 Misc Forms were placed and aggregate was present and compacted. Left a voicemail informing them that they needed to cover the approach to prevent freezing. RP 1-21-21

Informational:
2 Misc Finished driveway meets LS specs. RP 1-29-21

Comments: