



Jan 27, 2021

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

RE: Field Issue of spacer block addition for trusses C9 and C10 for Lot # 44 Hawthorne Ridge – 1519 SW Arbor Falls Dr. Lee's Summit, MO 64082 – Permit # PRRES20202304

This letter addresses the addition of a spacer block for trusses C9 and C10 to connect trusses to the double rim joist above the owner entry.

- Install (4) 3" screws per spacer block.
- It is structurally acceptable to install a spacer block of $\frac{3}{4}$ " – 1" depth to connect C9 and C10 trusses spanning approximately 14'4" with the double #2 2x10 rim joist above the owner entry.
- Trusses have approximately 630# reaction at the connection.

Sincerely,

Bradley Huxol, PE

