

Temporary Certificate of Occupancy

Permit #: PRCOM20191955
Address: 920 NE DEERBROOK ST, LEES SUMMIT, MO 64086
Inspected On: Friday, January 29, 2021
Inspected By: Khanh Nguyen
Expiration Date: 2/5/2021 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Temporary C of O	Friday, January 29, 2021

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">-Provide approval from: Water dept, Engineering, and Planning.-Provide 3rd party SI approval for footing and foundation and structural framing-Lower the water heater P/T valve discharge pipe down to pan-Complete mechanical exhaust roof flashing-Secure all CU LFNC raceways within 12" of disconnects-Engineer address roof support girder above 3186-Screw top floor purlin support posts to anchor brackets with 4 screws-Each X bracing strap requires 2 at ends and 1 at each column-Submit elevator certification-Protect electrical service equipment from physical damage-Install listed rebar grounding clamp and provide access to service |
|---|------|--|

disconnect enclosure; a screw missing at furnace room P2 panel cover