

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202889
Address: 3100 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Patrick Schonfeldt	Failed	Monday, February 01, 2021

Corrective Action Required:

1	Misc	-GAS PRESSURE AT 3 PSI, MUST MAINTAIN 10 PSI FOR TEST
---	------	---

Comments: