

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201867
Address: 504 NW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|-----------------|----------|----------------------------|
| Occupancy Inspection - Codes Residential | Michael Harkins | Failed | Tuesday, February 02, 2021 |

Corrective Action Required:

| | | |
|---|-----------------------------|---|
| 1 | Miscellaneous Correction | 504 main Occupancy ** PAY ALL FEES BEFORE FINAL ** -Submit as graded plot plan for review - Driveway & Sideway inspections pending - Complete gutters & downspouts Provide final grade sod & splash blocks Sump pump discharge shall be 36" from foundation Remove construction debris from job site |
|---|-----------------------------|---|

Comments: