CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201458

Address: 4412 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Codes Patrick Schonfeldt Temporary C of O Wednesday, February

Residential 03, 2021

Corrective Action Required:

1 Misc -Complete final grade and sod

-splash blocks at all downspout and sump pump discharge locations,

minimum 36" distance from foundation

-Guardrail required at front porch, more than 30" from grade, R312.1.1 measured vertically to the floor or grade below at any point within 36 inches

(914 mm) horizontally to the edge of the open side

OK FOR TCO -TCO EXPIRES 2/24/21

Comments: