

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20201877
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Construction Inspection	John Jackson	Partial	Wednesday, February 03, 2021

Informational:

1 Misc

2/2/21 Tuesday

Contractor (Brian/Holthouse) performed tie-in at the three location as-per project plans.

Informational:

2 Misc

2/3/21 Wednesday

Contractor (Brain/Holthouse) fixings the rubber seal gasket on the Fire Hydrant at NE Freehold Dr. & NE Goshen Dr. that was broken when the hydrant was turned.

Comments: